

VAPOR DRIVE →

PANEL THICKNESS (T)

COLD

COLDER

SEALANT IN SIDE JOINT

SEALANT (NBTC)

SLIP SHEET (NBTC)

FINISH FLOOR

FLOOR INSULATION (NBTC)

#12-14 X 1" HWH TYPE 3 SELF-DRILLING FASTENER @ HIGH CELLS (4 PER PANEL)

FIELD CUT THERMAL NOTCH (MIN. 5/8" DEEP)

16 GA. GALV. BASE CHANNEL

VAPOR BARRIER (NBTC)

FIELD APPLIED CONTINUOUS BEAD OF NON-CURING SEALANT TO DAM END OF PANEL JOINT

SET CHANNEL IN URETHANE SEALANT

CONCRETE FASTENER (NBTC)

NBTC = NOT BY TRUECORE



INTERIOR PARTITION BASE FREEZER / COOLER

DRAWN BY:
DBN

DATE:
M-D-Y

DRAWING NO.:

B5